## Telephone (609) 588-0011

## LECO LABORATORY

3123 Klockner Road Trenton, New Jersey 08690 Laboratory I.D. # NJ11106

CYO of Mercer County 920 South Broad Street Trenton, NJ 08611

Date Collected: **3-16-2021** Time Collected: **8:34am** 

Matrix: Water

Source: Church Child Care Area

Point of Collection: Girl's Lavatory Sink

Sampled by: Owner

Analysis By: Certified Lab ID # NJ03886

LECO Sample #: L0752114

Parameter/Method		Limit	Result
Lead (SM 3113B)		0.015 mg/L	<0.002 mg/L
Copper (SM 3111B)		1.30 mg/L	<0.10 mg/L
>= greater than	<= less than		

Remarks:

Both parameters tested meet the requirement established by the NJDEP.

Date: March 23, 2021

By: \_\_\_\_\_ Donald B. Lilley/Director